



SOUTHERN CALIFORNIA PUBLIC POWER AUTHORITY

REQUEST FOR PROPOSAL (RFP)

Linden Wind Power Project

WEC Maintenance Agreement RFP

Responses to Clarification Questions

1. Q: Has SCCPA already made physical work purchases to qualify for PTC?
A: No
2. Q: Is SCCPA able to commit to new or additional physical work purchases by the end of January to qualify for PTC?
A: Before the RFP is awarded, SCPPA plans to purchase, at a minimum, pitch motors, blade bearings, and gearboxes. These parts may be stored until a respondent is selected from the RFP to commence the proposed scope of work. The rest of the equipment will need to be purchased after the RFP is awarded and site assessment is completed.
3. Q: Could you share the target budget expected for each WTG to qualify for PTCs based on 80/20 analysis requirements?
A: The target budget should align with industry standard for turbines of similar make and age as those at currently at Linden. LADWP aims to proactively replace known equipment and components exhibiting issues and aging components that can begin exhibiting issues over the next several years to qualify for the PTCs.
4. Q: Would remanufactured-like-new components be permitted for use in the WTGs under the requested Proactive Maintenance scope?
A: Proactive Maintenance scope must meet the requirements of all IRS PTC guidelines for LADWP to qualify for PTC reimbursements.
5. Q: Please clarify the qualifications of the existing PRC-029 exemption. What is/are the hardware limiter(s) which is enabling the current exemption for the wind farm?
A: A contractor has been procured to perform an analysis of the Linden site for PRC compliance. Work is expected to start in January 2026.
6. Q: What mechanical/electrical/structural changes could be implemented at the WTGs without impacting the current PRC-029 exemption for the wind farm?
A: Discussion in NERC workshops on this have not been definitive and are ongoing. As stated in the RFP, it is expected for proposals to include strategies for LADWP to meet NERC compliance requirements based on the proposed scope of work. If exemptions are not needed, the proposal should explicitly state why. If exemptions are required, the proposals should detail plans to assist

LADWP with obtaining those exemptions. All proposers are expected to stay up-to-date with the latest developments on NERC requirements.

7. Q: Can SCPPA provide a Word version of the WEC Maintenance Agreement for markup of exceptions.

A: A Word Version of the WEC Maintenance Agreement has been posted with the RFP.